

2019 Water Quality Report for CITY OF WATERVLIET


This report covers the drinking water quality for CITY OF WATERVLIET for the 2019 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2019. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

Your water comes from 3 WELLS groundwater wells, each over 176 FEET drawing from PAW PAW LAKE watershed. The State performed an assessment of our source water in 2003 to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is WELL PW-1 AND PW-2 and PW-4 have a moderate susceptibility while PW-3 possesses a high susceptibility to get a copy of this report call city hall. WE HAVE ALSO PUT IN A NEW IRON REMOVAL PLANT IN WHICH WE HAVE BEGUN CHLORINATING AND IT WENT ON LINE IN THE MONTH OF OCTOBER OF 2014 WELLS PW-1 AND PW-2 AND PW-4 ARE RUN TO THE IRON PLANT AND PW-3 IS A STAND BY WELL ONLY TO BE USED IN A EMERGENCY SITUATION AND SINCE WE HAVE BEEN TESTING AT THE PLANT WE HAVE BEEN TAKING 98% OF THE IRON OUT OF OUR OUTGOING WATER INTO THE SYSTEM THEREFORE GIVING US THE ABILITY PRODUCE AND SERVE THE COMMUNITY A MUCH BETTER PRODUCT THAN PREVIOUSLY to give you a better source of drinking water . WE WERE TESTED FOR PFAS ON 7-23-18 AT THE IFP PLANT THE CONCENTRATIONS OF PFAS IN THESE SAMPLES ARE WELL BELOW THE USEPA LHA AND ARE NOT EXPECTED TO RESULT IN ADVERSE HEALTH EFFECTS AS LONG AS THE CONCENTRATIONS ARE SHOWN TO REMAIN BELOW THE LHA OVER TIME.

If you would like to know more about the report please contact city hall or call MARK BOLIN AT 269-463 -4041

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's **Safe Drinking Water Hotline (800-426-4791)**.

- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC



guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.
- Contaminants that may be present in source water include:
 - T **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
 - T **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
 - T **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.

- T **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- T **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2019 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2019. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Residual Disinfectant Level (MRDL):** means the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** means the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **N/A:** Not applicable **ND:** not detectable at testing limit **ppb:** parts per billion or micrograms per liter **ppm:** parts per million or milligrams per liter **pCi/l:** picocuries per liter (a measure of radioactivity).
- **Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Regulated Contaminant	MCL	MCLG	Highest Level Detected	Range	Year Sampled	Violation Yes / No	Typical Source of Contaminant
Arsenic (ppb)	10	0	6	0-6	9-21-17	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.43	0.13-0.43	9-16-14	No	Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.31	0.17-0.31	2019	NO	Erosion of natural deposits. Discharge from fertilizer and aluminum factories.
TTHM – Total Trihalomethanes (ppb)	80	N/A	24.8	14.0-24.8	2019	NO	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	9	6-9	2019	NO	Byproduct of drinking water disinfection
Chlorine (ppm)	MRDL	MRDLG	.52	0.48-0.56	2019	NO	Water additive used to control microbes
	4	4					
Radioactive Contaminant	MCL	MCLG	Highest Level Detected	Range	Year Sampled	Violation Yes / No	Typical Source of Contaminant
Combined radium (pCi/L)	5	0	2.04	0.72-2.04	9-25-17	NO	Erosion of natural deposits
Contaminant Subject to AL	Action Level	MCLG	90% of Samples ≤ This Level		Year Sampled	Number of Samples Above AL	Typical Source of Contaminant
Lead (ppb) **	15	0	2ppb		2018	0	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	1.3	1.3	0.17PPM		2018	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

Special Monitoring and Unregulated Contaminant *	Average Level Detected	Range	Year Sampled	Comments
Sodium (ppm)	24	23-25	2019	Typical source is erosion of natural deposits

Information about lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. CITY OF WATERVLIET is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Microbial Contaminants	MCL	MCLG	Number Detected	Violation Yes / No	Typical Source of Contaminant
Total Coliform Bacteria	>1 positive monthly sample (>5.0% of monthly samples positive)	0	0	NO	Naturally present in the environment
Fecal Coliform and <i>E. coli</i>	Routine and repeat sample total coliform positive, and one is also fecal or <i>E. coli</i> positive	0	0	NO	Human and animal fecal waste

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

OUR WATER SUPPLY HAS 410 SUSPECTED LEAD SERVICE LINES AND 336 PARTIAL LEAD LINES SUSPECTED 67 LEAD FREE LINES AND 4 REPLACEMENT FOR A TOTAL OF 817 SERVICE LINES

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at CITY HALL 158 WEST PLEASANT This report will not be sent to you.

We invite public participation in decisions that affect drinking water quality. THE CITY COUNCIL MEETING ARE HELD THE FIRST TUESDAY OF EACH MONTH AT 6:30.. For more information about your water, or the contents of this report, contact MARK BOLIN AT 269-463-4041. For more information about safe drinking water, visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/.